

Facility Summary in Madison County in the City of Alder

Location: ALDER MARKET LLC  
2325 Hwy 287  
Alder, MT 59710 Madison

Facility Code: 24625  
Last Inspected On: 04/13/2021  
System Facility ID:28-04167  
Operating Permit Renewal Date: 05/15/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Alder Market LLC	4068425679
Operator Contact:	William Caldwell	4069259713

Owner/Operator: Alder Market LLC

William Caldwell, UST Class A Operator

William Caldwell, UST Class B Operator

Tank Code	S3	Tank Age	34	Tank Installed Date	07/01/1988	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	385	Spill Test Date		Piping Installed Date	11/14/2017	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	04/13/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	11/14/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S4	Tank Age	34	Tank Installed Date	07/01/1988	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	386	Spill Test Date		Piping Installed Date	11/14/2017	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	04/13/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2900	ATG Test Date		Line Tightness Test Date	11/14/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Madison County in the City of Cameron

Location: WARREN MILLER LODGE  
Seven Bears Trl  
Cameron, MT 59720 Madison

Facility Code: 30806  
Last Inspected On: 04/01/2021  
System Facility ID:60-15020  
Operating Permit Renewal Date: 04/08/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Yellowstone Club 4069932422

Operator Contact: Joe Robillard

Owner/Operator: Yellowstone Club

Dan Nitsche, UST Class B Global Operator  
Joe Robillard, UST Class A Operator

Tank Code	02	Tank Age	5	Tank Installed Date	08/14/2017	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5766	Spill Test Date	11/22/2021	Piping Installed Date	08/14/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date	09/18/2017	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	OPW/EECO 1500				

Facility Summary in Madison County in the City of Ennis

Location: ROCKY MOUNTAIN SUPPLY INC ENNIS  
4997 US Hwy 287 N  
Ennis, MT 59729 Madison

Facility Code: 30512  
Last Inspected On: 09/02/2020  
System Facility ID:56-13826  
Operating Permit Renewal Date: 11/29/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Supply Inc 4063884009

Operator Contact: Greg Stearman;Jason Rorabaugh 4063884008

Owner/Operator: Rocky Mountain Supply Inc

Greg Stearman, UST Class A Operator

Greg Stearman, UST Class B Operator  
Jason Rorabaugh, UST Class A Operator

Tank Code	01	Tank Age	25	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1768	Spill Test Date	09/02/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/02/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	07/22/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/02/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	25	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1769	Spill Test Date	09/02/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/02/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	07/22/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/02/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	25	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1770	Spill Test Date	09/02/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/02/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	07/22/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	09/02/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	25	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1771	Spill Test Date	09/02/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/02/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	07/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/02/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	05	Tank Age	25	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1772	Spill Test Date	09/02/2020	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/02/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	03/04/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/02/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	25	Tank Installed Date	07/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1773	Spill Test Date	01/19/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	8000	ATG Test Date		Line Tightness Test Date	03/02/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/02/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

**Facility Summary in Madison County in the City of Ennis**

**Location:** TOWN PUMP INC ENNIS  
116 W Main St  
Ennis, MT 59729 Madison

**Facility Code:** 24722  
**Last Inspected On:** 08/29/2022  
**Operating Permit Renewal Date:** 10/27/2024  
System Facility ID:28-08698

**Note:** Inspection is due 90 days before the Operating Permit Renewal Date.

**Owner Operator Contact:** Ennis 1 Town Pump LLC 4064976700

**Operator Contact:** Trent Biggers

**Owner/Operator:** Ennis 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	42	Tank Installed Date	04/14/1980	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2529	Spill Test Date	07/07/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	04/22/2021	Tank/Piping CP Test Date	04/22/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/22/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	30	Tank Installed Date	04/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2530	Spill Test Date	07/07/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/22/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/22/2021	Line Tightness Test Date	07/13/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/22/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	30	Tank Installed Date	04/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2531	Spill Test Date	07/07/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/22/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/22/2021	Line Tightness Test Date	07/13/2015	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/22/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	30	Tank Installed Date	04/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2532	Spill Test Date	07/07/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/22/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/22/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	20	Tank Installed Date	10/16/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4734	Spill Test Date	04/22/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/03/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	04/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/22/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	08	Tank Age	20	Tank Installed Date	10/16/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4735	Spill Test Date	07/07/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	04/22/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/22/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Madison County in the City of Norris

Location: MCLEOD MERCANTILE SW CORNER  
6533 US Hwy 287  
Norris, MT 59745 Madison

Facility Code: 30774  
Last Inspected On: 11/04/2021  
System Facility ID:56-14138  
Operating Permit Renewal Date: 02/28/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: A M Welles Inc

Operator Contact: Katie Burtchett;Marvena Rice;Patricia Lehman4065803664;4066853372

Owner/Operator: A M Welles Inc

Katie Burtchett, UST Class A Operator  
Katie Burtchett, UST Class B Operator  
Marvena Rice, UST Class A Operator  
Patricia Lehman, UST Class A Operator

Tank Code	06	Tank Age	31	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2712	Spill Test Date	11/04/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/04/2021	Tank/Piping CP Test Date	11/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	07	Tank Age	31	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2713	Spill Test Date	03/31/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/04/2021	Tank/Piping CP Test Date	11/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	31	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2714	Spill Test Date	11/04/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	11/04/2021	Tank/Piping CP Test Date	11/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	31	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2715	Spill Test Date	11/04/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	11/04/2021	Tank/Piping CP Test Date	11/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	10	Tank Age	31	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2716	Spill Test Date	11/04/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	11/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	11	Tank Age	31	Tank Installed Date	07/01/1991	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2717	Spill Test Date	11/04/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	14	Tank Age	18	Tank Installed Date	07/02/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4892	Spill Test Date	03/31/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/04/2021	Tank/Piping CP Test Date	11/04/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/02/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2021			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Madison County in the City of Sheridan

Location: A M WELLES 95 Tuke Ln Sheridan, MT 59749 Madison	System Facility ID:60-15002	Facility Code: 30796 Last Inspected On: 08/04/2022 Operating Permit Renewal Date: 09/09/2025
Note: Inspection is due 90 days before the Operating Permit Renewal Date.		

Owner Operator Contact: A M Welles Inc

Operator Contact: Sandy Flager;Tim Nicholls

Owner/Operator: A M Welles Inc

- Sandy Flager, UST Class A Operator
- Sandy Flager, UST Class B Operator
- Tim Nicholls, UST Class A Operator
- Tim Nicholls, UST Class B Operator

Tank Code	02	Tank Age	17	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5007	Spill Test Date	08/04/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	08/04/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	08/04/2022	Line Tightness Test Date	12/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	17	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5008	Spill Test Date	08/11/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	08/04/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/04/2022	Line Tightness Test Date	12/17/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	17	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5009	Spill Test Date	08/11/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/04/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7000	ATG Test Date	08/04/2022	Line Tightness Test Date	12/17/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	08/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	05	Tank Age	17	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5010	Spill Test Date	08/04/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/04/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	08/04/2022	Line Tightness Test Date	12/11/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	17	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5011	Spill Test Date	08/04/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/04/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/04/2022	Line Tightness Test Date	12/23/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	01	Tank Age	17	Tank Installed Date	09/15/2005	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	5044	Spill Test Date	08/11/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date	08/04/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	08/04/2022	Line Tightness Test Date	12/05/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Madison County in the City of Sheridan

Location: MCLEOD MERCANTILE 2802043 202 S Main St Sheridan, MT 59749 Madison	Facility Code: 24575 Last Inspected On: 03/10/2021 Operating Permit Renewal Date: 06/09/2024
System Facility ID:28-02043	
Note: Inspection is due 90 days before the Operating Permit Renewal Date.	

Owner Operator Contact: AM Welles Inc dba McLeod Merc	4066853372
---	------------

Operator Contact: Sandy Flager
--------------------------------

Owner/Operator: AM Welles Inc dba McLeod Merc
Sandy Flager, UST Class A Operator
Sandy Flager, UST Class B Operator

Tank Code	13	Tank Age	2	Tank Installed Date	11/19/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5999	Spill Test Date	10/16/2020	Piping Installed Date	11/19/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/05/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date		Line Tightness Test Date	11/27/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/16/2020			ATG Type	Franklin Fueling Systems;/Incon;/Incon/TS-550 EVO				
Tank Code	14	Tank Age	2	Tank Installed Date	11/19/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	6000	Spill Test Date	10/16/2020	Piping Installed Date	11/19/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/05/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	11/27/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/16/2020			ATG Type	Franklin Fueling Systems/;Incon/I ncon/TS-550 EVO				
Tank Code	15	Tank Age	2	Tank Installed Date	11/19/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6001	Spill Test Date	10/16/2020	Piping Installed Date	11/19/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/05/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/27/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/16/2020			ATG Type	Franklin Fueling Systems/;Incon/I ncon/TS-550 EVO				
Tank Code	16	Tank Age	2	Tank Installed Date	11/19/2020	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6002	Spill Test Date	10/16/2020	Piping Installed Date	11/19/2020	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/05/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/27/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/16/2020			ATG Type	Franklin Fueling Systems/;Incon/I ncon/TS-550 EVO				

**Facility Summary in Madison County in the City of Twin Bridges**

**Location:** BOS CHEVRON AND TIRE SERVICE  
100 S Main St  
Twin Bridges, MT 59754 Madison

System Facility ID:28-07478

**Facility Code:** 24698  
**Last Inspected On:** 10/01/2019  
**Operating Permit Renewal Date:** 11/08/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bo Mailey 4066845611

Operator Contact: Bo Mailey 4066845611

Owner/Operator: Bo Mailey  
Bo Mailey, UST Class A Operator  
Bo Mailey, UST Class B Operator

Tank Code	05	Tank Age	23	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3913	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	06	Tank Age	23	Tank Installed Date	01/01/1999	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3914	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Madison County in the City of Twin Bridges

Location: THREE RIVERS QUICK STOP  
325 S Main St  
Twin Bridges, MT 59754-9740 Madison

System Facility ID:28-10708

Facility Code: 24759  
Last Inspected On: 01/19/2022  
Operating Permit Renewal Date: 01/19/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Danny Hanson

4066845733

Operator Contact: Danny Hanson;Gena Nordquist

4066845733

Owner/Operator: Danny Hanson

Danny Hanson, UST Class A Operator  
Gena Nordquist, UST Class A Operator  
Gena Nordquist, UST Class B Operator

Tank Code	04	Tank Age	30	Tank Installed Date	10/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1816	Spill Test Date	07/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/19/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date	07/09/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2021			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco/EM C Basic				

Tank Code	05	Tank Age	30	Tank Installed Date	10/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1817	Spill Test Date	07/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/19/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/09/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/09/2021			ATG Type	Franklin Fueling Systems/TS-LLD;Gilbarco/EM C Basic				

Facility Summary in Madison County in the City of Virginia City

Location: VILLAGE PUMP AND INFORMATION CENTER  
221 E Wallace St  
Virginia City, MT 59755-0338 Madison

System Facility ID:28-05399

Facility Code: 24653  
Last Inspected On: 09/08/2022  
Operating Permit Renewal Date: 01/07/2026

**Note: Inspection is due 90 days before the Operating Permit Renewal Date.**

**Owner Operator Contact:** Montana Heritage Preservation and Development Commission 4068435655  
Virginia City

**Operator Contact:** Becky DiGiovanna;Kate Steeley 4066602195;4068435247

**Owner/Operator:** Montana Heritage Preservation and  
Development Commission Virginia City  
Becky DiGiovanna, UST Class A Operator  
Becky DiGiovanna, UST Class B Global Operator  
Kate Steeley, UST Class A Operator  
Kate Steeley, UST Class B Global Operator

Tank Code	04	Tank Age	3	Tank Installed Date	02/05/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5860	Spill Test Date	11/10/2021	Piping Installed Date	02/05/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/05/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/08/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	09/08/2022	Line Tightness Test Date	02/11/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/10/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD;Veeder Root/TLS-450				
Tank Code	05	Tank Age	3	Tank Installed Date	02/05/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5861	Spill Test Date	11/10/2021	Piping Installed Date	02/05/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/05/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/08/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	09/08/2022	Line Tightness Test Date	02/11/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	11/10/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/8590 Series DPLLD;Veeder Root/TLS-450				
--	--	--------------------	------------	--	--	----------	--	--	--	--	--